CERTIFICATE



of Conformity

Registration No.:

AK 60094498 0001

Report No.:

28106659 001

Holder:

Elpower S.r.l. Via Beggiato 23 36025 Noventa Vicentina VI

Product:

Electrical Equipment

Grid tied inverter

Identification:

Trademark:

ELPOWER

Model:

Cleanverter 40TL Cleanverter 50TL Cleanverter 60TL Cleanverter 80TL Cleanverter 100TL

Remark:

NS protection functions not integrated.

Functions are covered by an external device.

Tested acc. to:

VDE-AR-N 4105/08.11

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 17.06.2014

Marco Piva

Certification Body and LGA Produ

VRheinland

ertifizierungsst

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



Extract from Test report for unit certificate: 28106659 001

"Determination of electrical properties"

Seite 1 von 7 Page 1 of 7

Extract No: 1 _ Annex F.3 (VDE-AR-N 4105)

Type of System:	Grid tied inverter	Grid tied inverter	
System Manufacturer:	EL POWER S.r.I	EL POWER S.r.I	
Manufacturer data:	Via Beggiato, 23 - 36025 Noventa Vicentina (VI)		
Reference test report:	28106659 001	28106659 001	
Measuring period:	From 20/01 to 27/01 - 2014	From 20/01 to 27/01 - 2014	
Active Power [P _{Emax}]: (nominal power at reference conditions)	Modelle CLEANVERTER 100TL	P _{Emax} 100 KW	
	CLEANVERTER 80TL	80 KW	
	CLEANVERTER 60TL	60 KW	
	CLEANVERTER 50TL	50 KW	
	CLEANVERTER 40TL	40 KW	
Rated Voltage:	3-phase devices		
	230 V (Phase/ Neutral)		
	400 V (Phase/Phase)		

Note: test performed on model CLEANVERTER 100TL. The test result can be extended on all model of the same product family. The family product model is made by the following products:

CLEANVERTER 80TL, CLEANVERTER 60TL, CLEANVERTER 50TL, CLEANVERTER 40TL